

AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT				1. CONTRACT ID CODE		PAGE OF PAGES 1 2	
2. AMENDMENT/MODIFICATION NO. 0005		3. EFFECTIVE DATE 21-May-2002		4. REQUISITION/PURCHASE REQ. NO.		5. PROJECT NO.(If applicable)	
6. ISSUED BY CONTRACTING DIVISION USACE - ST PAUL 190 5TH STREET ST PAUL MN 55101-1638		CODE DACW37		7. ADMINISTERED BY (If other than item 6) See Item 6		CODE	
8. NAME AND ADDRESS OF CONTRACTOR (No., Street, County, State and Zip Code)				X		9A. AMENDMENT OF SOLICITATION NO. DACW37-01-B-0011	
				X		9B. DATED (SEE ITEM 11) 23-Apr-2002	
						10A. MOD. OF CONTRACT/ORDER NO.	
						10B. DATED (SEE ITEM 13)	
CODE		FACILITY CODE					
11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS							
<input checked="" type="checkbox"/> The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offer <input type="checkbox"/> is extended, <input checked="" type="checkbox"/> is not extended. Offer must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended by one of the following methods: (a) By completing Items 8 and 15, and returning <u>1</u> copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or telegram which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment you desire to change an offer already submitted, such change may be made by telegram or letter, provided each telegram or letter makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.							
12. ACCOUNTING AND APPROPRIATION DATA (If required)							
13. THIS ITEM APPLIES ONLY TO MODIFICATIONS OF CONTRACTS/ORDERS. IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.							
A.THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 10A.							
B.THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES (such as changes in paying office, appropriation date, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(B).							
C.THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:							
D.OTHER (Specify type of modification and authority)							
E. IMPORTANT: Contractor <input type="checkbox"/> is not, <input type="checkbox"/> is required to sign this document and return _____ copies to the issuing office.							
14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.) The bid opening remains unchanged.							
Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect.							
15A. NAME AND TITLE OF SIGNER (Type or print)				16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print)			
15B. CONTRACTOR/OFFEROR _____ (Signature of person authorized to sign)		15C. DATE SIGNED		16B. UNITED STATES OF AMERICA BY _____ (Signature of Contracting Officer)		16C. DATE SIGNED	

SECTION SF 30 BLOCK 14 CONTINUATION PAGE

SUMMARY OF CHANGES

1. Changes to Section 15131

Paragraph 3.2.1 Dry Tests: Delete the third sentence that reads, "After pumping unit has been completely assembled, including all rotating elements..." in its entirety and replace with the following: "After installation of all pumps, including the lubrication system, operate each pump for a period of 2 minutes in the dry."

2. Changes to Drawings

Drawing R-P-GF-64/616, Coordinate F-2, Add the Following Note 2: "The Contractor shall submit shop drawings of the pump discharge system for approval. See drawings 64/584 and 64/585 for plan and profile of the pump station and gatewell. Alternate acceptable means of connection to the gatewell and pump station include using EBAA Iron Flex-Tend expansion joints (restrained). The expansion joints shall be a double ball design at the gatewell and a single ball design at the pump station. The expansion joints shall transition into the restrained joint pipe system. Another acceptable means of connection to the gatewell and pump station is to use ball and socket, ductile iron river crossing pipe between the pump station and gatewell. The Contractor may transition to the US Pipe TR FLEX pipe system (or equal), however, at least two ball and socket joints shall be provided at the gatewell. At least one ball and socket joint shall be provided at the pump station. All joints shall be restrained."

Drawing R-P-GF-64/616, Coordinate F-2, Add the Following Note 3: "At the discharge pipe penetrations in the gatewell, provide a ductile iron wall sleeve (or core drilled opening) and double Link Seals (or equal)."

Drawing R-P-GF-64/616, Coordinate F-2, Add the Following Note 4: "Provide a flap gate on the termination of the 6" sump pump discharge line."

Drawing R-P-GF-64/600, Section B add "Belting is attached with 1 1/2" by 1/8" Becker Bar bolted @ 12" OC"

3. General Questions

Q.) Sections A & D show skin plate on one side (N.S.). All other sections show skin plate on (F.S.) & elevation is questionable.

R.) Drawing convention for horizontal cuts is looking down from behind the bulkhead. Sections A & D show correct skin plate location.